

FIGURE 1




FIGURE 2

Honeywell
T7350 Configuration Tool
Version: 0.0.d.18d

Override Monitor Data
Set Clock Holidays
Temp SetPts Wkly Schedule
Upload Config
New Config

▼ Select Existing Config

FIGURE 3a

Summary ▼ Select Setup

C nfig Name: New Config
Description:
120 character description which is.....
user entered.....

Model: ▼ Mod1_Basic
Control: Standard Heat Pmp
Cnfig ID: 00

DownLd
Back Next Save SaveAs

FIGURE 3b

Honeywell
T7350
Configuration Tool
Version: 0.0.d.5

Temp SetPts Holidays
Set Clock Wkly Schedule
Monitor Data Upload Config
New Config

▼ Select Existing Config

FIGURE 4a

Honeywell
T7350
Configuration Tool

DEFAULT
Example1
Example2
Example3
Example4
New Config

Holidays
Schedule
d Config

FIGURE 4b

Summary

C nfig Name: Example2
Description:
T7350B model supports: 6 relays.....
remote space sensor, DAT, OAT.....

Model: ▼ T7350B (6DigOut)
Control: Standard Heat Pmp
Cnfig ID: 22

DownLd
Back Next Save SaveAs

FIGURE 4c

Summary

Config Name: Example2
Description:
T7350B model supports: 6 relays.....
remote space sensor, DAT, OAT.....

Connecting to T7350

**Please connect PDA
serial port to the T7350
using serial cable.**

OK Cancel

FIGURE 4d




FIGURE 5a




FIGURE 5b




FIGURE 5c




FIGURE 6a




FIGURE 6b




FIGURE 6c


Summary	
Config Name:	XYZ
Description:	A short description of customer XYZ configuration.
Connecting to T7350	
 Please connect PDA serial port to the T7350 using serial cable.	
OK	Cancel

FIGURE 6d

File	Connect	Setup	Help
Conf	Download	Customer XYZ	
Desc	Upload	Option.....	
120.d	Monitor	
	Set Clock		
	Calibrate		
Model:			
Control:			
Down Load		Save As	
Next		Save	

FIGURE 7a


Room Temp Calibrate	
Actual Value: 68.4 F	
Edit Value: 68.4  F	
Offset: -3 F	
Calibrate	Refresh
Close	

Figure 7b

Honeywell	
T7350 Configuration Tool	
Version: 0.0.d.18d	
Override	Monitor Data
Set Clock	Holidays
Temp SetPts	Wkly Schedule
Upload Config	
New Config
▼ Select Existing Config	

FIGURE 7a


Honeywell	
T7350	
Configuration Tool	
Version: 0.0.d.5	
Connecting to T7350	
 Please connect PDA serial port to the T7350 using serial cable.	
OK	Cancel

FIGURE 8b

Summary

Config Name: U04/09/03 11:05

Description:
 Upload: 04/09/2003, 11:05 am
 Fmwrv: 0.0.14, ComV: 1002
 rePrgrV: 1, SubBaseID: 3

Model: ▼ T7350D,3H3C,RH

Control: **Standard** Heat Pmp

CnfgID

DownLd

Back Next Save SaveAs

FIGURE 8c

Honeywell

T7350 Configuration Tool
 Version: 0.0.d.18d

Override Monitor Data

Set Clock Holidays

Temp SetPts Wkly Schedule

Upload Config

New Config

▼ Select Existing Config

FIGURE 8d

Monitor Data

SubBaseID: T7350D,3H3C,RH
 FirmwareVersion: 0.0.19

=====

RoomTemperature: 79.2 F
 EffectiveSetPoint: 75.0 F

=====

RoomRH: 31 %
 Dehumidification: Off

=====

DischargeAirTemp: 70.3 F

Update Close

Figure 8e

Summary

Config Name: Example3

Description:
 T7350C SmartStat supports: 6
 Relays, remote space sensor, DAT,
 OAT, RH, Occ sensor

Model: ▼ T7350C (6DigOut+RH)

Control: **Standard** Heat Pmp

Cnfg ID: 23

DownLd

Back Next Save SaveAs

Figure 9a

Inputs

RoomTemp: **Local** Remote
 Rmt+StPt

Room **Local** Remote

Rel Humidity: **None**

Occ Sensor: **None** Remote

Discharge

AirTemp: **None** Remote

Outdoor **None** Remote

AirTemp:

Back Next

FIGURE 9b

Outputs

AuxDO: **Time of Day**
 Economizer
 Dehumid Hot Gas BP
 Simple Dehumid

Back Next

FIGURE 9c

Cooling Config

Stages: 0 1 2 3

Cooling: Std 3 cph

Response: Fast 4 cph

☒ Enable OAT Lockout
OAT SetPt 35 F

☒ Enable DAT Low Limit
DAT SetPt 45 F

Back Next

FIGURE 9d

Heating Config

Stages: 0 1 2 3

Heating: Std 3cph Med 6cph

Response: Fast 9cph Fast!!20cph

☒ Enable OAT Lockout
OAT SetPt 70 F

☒ Enable DAT High Limit
DAT SetPt 110 F

Back Next

FIGURE 9e

Fan

FanSwitch: On Auto

FanOperation: Conventional Electric Heat

Heat: No Extended Op Extend 90 sec

Cool: No Extended Op Extend 90 sec

Back Next

FIGURE 9f

Weekly Schedule

▼ Select New Schedule

SaveRs Delete Modify

MON 08:00 am OCC
---- 10:00 pm UNOCC
TUE 08:00 am OCC
---- 10:00 pm UNOCC
WED 08:00 am OCC
---- 10:00 pm UNOCC
THU 08:00 am OCC

Back Next Download

FIGURE 9g

Modify Schedule

Day: ▼ Monday

Event#	-- Mode --	-- Time --
1	▼ Occupied	08:00 am
2	▼ Unoccupied	10:00 pm
3	▼ None	12:00 am
4	▼ None	12:00 am

CopyDayTo ☐ Sun ☐ Sat ☐ Hol
☐ M ☐ T ☐ W ☐ T ☐ F

OK

FIGURE 9h

SetPoints

	Heating	Cooling
Occupied	70 F	75 F
Standby	67 F	78 F
UnOcc	55 F	85 F
Occupied SetPt Stops	55 F	85 F

TempOverride: ▼ 3 Hrs

Back Next Download

FIGURE 9i

Summary	
Config Name: ExampleModelID	
Description: T7350D model supports: 6 Relays, remote space sensor, DAT, OAT, RH, Occ sensor	
Model: ▼ T7350D,3H3C,RH	
Control: Standard Heat Pmp	
CnfgID	
DownLd	
Back	Next Save SaveAs

FIGURE 9j

Summary	
Config Name: ExampleModelID	
Description: T7350D model supports: 6 Relays, remote space sensor, DAT, OAT, RH, Occ sensor	
Model: ▼ T7350D,3H3C,RH	
Control: Standard Heat Pmp	
CnfgID	
DownLd	
Back	Next Save SaveAs

FIGURE 10a

File	Com	Set	Sched	Opt
Config Name:	Home			
Description:	Summary			
T7350D model supports: 6 Relays, remote space sensor, DAT, OAT, RH, Occ sensor	Inputs			
	Outputs			
	Cooling			
	Heating			
Model: ▼ T7350D,3H3C,RH	Fan			
Control: Standard Heat Pmp	SetPoints			
CnfgID	Display			
	Dehumidification			
	EnergyMgmt			
	LoopTuning			
Back	Next Save SaveAs			

FIGURE 10b

File	Com	Set	Sched	Opt
Config Name: E>	Wkly Sched			
Description:	Recovery			
T7350D model supports: 6 Relays, remote space sensor, DAT, OAT, RH, Occ sensor	Holiday			
	DayLightSav			
Model: ▼ T7350D,3H3C,RH				
Control: Standard Heat Pmp				
CnfgID				
			DownLd	
Back	Next Save SaveAs			

FIGURE 10c

Display	
Units:	F C
Rm Temp:	Display NoDisplay
Occupied SetPoint Stops	
Min 55	Max 85
▼ F	▼ F
Clock:	AM/PM 24 hr
Key Pad:	▼ Enable All
SysSwitch:	▼ OFF
OK	



FIGURE 10d

Dehumidification	
High Limit:	65 %
Dehumid Options:	
<input checked="" type="checkbox"/> Min ON Time	▼ 5 min
<input checked="" type="checkbox"/> Reheat	
<input checked="" type="checkbox"/> Reset Temp SetPt	1 ▼ F
Spin Speed	
OK	1X 10X


FIGURE 10e

Energy Management

Demand Limit

Control Bump: 3   F

Power Failure

Seq Start:  0 sec

OK

Loop Tuning

	Heating	Cooling
TR	7	7 F
IT	1650	1650 sec
DT	0	0 sec

Anticipator Authority: 4

Apply To: **Htg** (Htg&Clg)

Spin Speed: **1X** (10X) (100X)

OK

Recovery		Cool		Heat	
ORT@Min:	90	▲	▼	0	F
Ramp Min:	3	▲	▼	5	F/hr
ORT@Max:	70	▲	▼	40	F
Ramp Max:	6	▲	▼	8	F/hr
LeadTime	-Cool-			-Heat-	
MaxRange	1.8 to 3.5			2.0 to 3.1 hr	
OK		LeadTimeInfo			

Day Light Saving

Start Month: ▼ Apr

Start Day: FirstSun ▲▼

Stop Month: ▼ Oct

Stop Day: LastSun ▲▼

Spin Speed


OK


1X 10X

Modify Holiday

▼ New Years Day
New Years Day

Start Month: ▼ Jan

Start Day: 1 

Duration: 1  Day

Spin Speed
1X 10X

OK




Figure 101




FIGURE 11a




FIGURE 11b




FIGURE 12a




FIGURE 12b

Open Configuration

Current: Example1

Save Current Config

Select Config:

- ABCRooftopGasHt
- Customer XYZ
- DEFAULT
- Example1
- Example2
- Example3
- Example4
- New Config

Cancel

Open

FIGURE 12c

Save Configuration As

Existing Configs:

- ABCRooftopGasHt
- Customer XYZ
- DEFAULT
- Example1
- Example2
- Example3
- Example4
- New Config

Cancel

SaveAs: Example1

FIGURE 12d

Delete Configuration

Select Config:

- ABCRooftopGasHt
- Customer XYZ
- Example1
- Example2
- Example3
- Example4
- New Config

Cancel

Delete

FIGURE 12e

Set Clock

T7350 Clock

05:25 pm WED 04/09/2003

Date Mode: MM/DD/YYYY

Day of Week

Method: Manual PDA Clock

Time: 02:26 pm

Date: 04/09/2003

Set Update Close

FIGURE 13

5:00 pm

Stat-Man

- All
- Games
- Honeywell Tools
- Main
- System
- Utilities
- Unfiled
- Edit Categories...

FIGURE 14a

Select

Honeywell

Thermostat

Configuration

Tool

File:

Config ID = 0

Upload Download

FIGURE 14b

Main File Set Up Schedule

Set Up

Thermostat Configuration Tool

File:

Config ID = 0

Upload **Download**

FIGURE 14c

Program

Day: **Sunday** **Set Points**

Event#	Day	Time
1	Tuesday	8:30 am
2	Thursday	5:30 pm
3	Friday	7:00 pm
4	Saturday	12:00 am

Do it 1 2 3 4 5 6 7

Copy Day To: ☐ ☐ ☐ ☐ ☐ ☐ ☐

Cancel **Done**

FIGURE 14d

Program

Day: **Sunday** **Set Points**

Event#	Mode	Time
1	Occupied	8:30 am
2	Unocc	5:30 pm
3	Standby	7:00 pm
4	None	12:00 am

Do it 1 2 3 4 5 6 7

Copy Day To: ☐ ☐ ☐ ☐ ☐ ☐ ☐

Cancel **Done**

FIGURE 14e

Program

Day: **Sunday** **Set Points**

Event#	Mode	Time
1	None	3:30 am
2	Occupied	5:30 pm
3	Standby	2:00 am
4	Unocc	2:00 am

Do it 1 2 3 4 5 6 7

Copy Day To: ☐ ☐ ☐ ☐ ☐ ☐ ☐

Cancel **Done**

FIGURE 14f

Program

Day: **Sunday** **Set Points**

Event#	Mode	Time
1	Occupied	8:30 am
2	Unocc	5:30 pm

Select Event Time

8 : **30** **AM** **PM**

OK **Cancel**


FIGURE 14g

Set Points

	Cooling	Heating
Occupied	72	70
Standby	75	68
Unoccupied	80	60

Cancel **OK**

FIGURE 14h



Installer Set Up


Temperature Units
☒ Deg F ☐ Deg C

Clock Format
☒ 12 Hr ☐ 24 Hr

Fan Behavior
☒ Continuous ☐ Intermittant

Program from Keyboard
☒ Yes ☐ No

FIGURE 14i



Set Up 2


Heat Stages
☒ 1 ☐ 2 ☐ 3

Cool Stages
☒ 1 ☐ 2 ☐ 3

Energize Fan For
☒ Cool Only ☐ Heat & Cool

Sensor Location
☒ Local ☐ Remote

FIGURE 14j




Load Program

Choose File

☒ Standard 1
☐ Target
☐ Wendy's 1
☐ Standard 2
☐ K-Mart Heatpumps
☐ Pay-less Shoes

FIGURE 14k




Select

Honeywell
 Thermostat
 Configuration
 Tool

File: Standard 1

Config ID = 0

FIGURE 14l



Save to File

Save the current Thermostat
 configuration as file name:

.....

FIGURE 14m

Weekly Schedule

▼ Select New Schedule

.....

SaveAs Delete Modify

MON 08:00 am OCC
 ---- 10:00 pm UNOCC
 TUE 08:00 am OCC
 ---- 10:00 pm UNOCC
 WED 08:00 am OCC
 ---- 10:00 pm UNOCC
 THU 08:00 am OCC ↓

Back Next Download

Figure 14n

Holiday

▼ Select New Holiday Group

.....

SaveAs Delete Modify

New Years Day
 Jan 1, Dur:1
 Memorial Day
 May LastMon, Dur:1
 Independence Day
 Jul 4, Dur:1
 Labor Day ↓

OK Download

Figure 14o

SetPoints

	Heating	Cooling
Occupied	70	75 F
Standby	67	78 F
UnOcc	55	85 F
Occupied SetPt Stops	55	85 F

TempOverride: ▼ 3 Hrs

Back Next Download

Figure 14p

File	Com	Set	Sched	Opt
Config	Nar	Home		
Description		Summary		
T7350D mod		Inputs		
remote spac		Outputs		
RH, Occ sens		Cooling		
		Heating		
Model: ▼		Fan		
Control: ▼		SetPoints		
CnfgID		Display		
		Dehumidification		
		EnergyMgmt		
		Loop Tuning		

Back Next Save SaveAs

Figure 14q

Honeywell

T7350 Configuration Tool

Version: 0.0.d.18d

Override Monitor Data

Set Clock Holidays

Temp SetPts Wkly Schedule

Upload Config

New Config

▼ Select Existing Config

Figure 14r

File	Com	Set	Sched	Opt
C n f	D w n l a d	mpleModelID		
Desc	Upload			
T735i	Monitor			
3Htg,	Set Clock	irts, 8 Relays:		
rema	Calibrate	an. Sensors:		
	Override	irture, DRT,		
Model: ▼ T735UD,3H3C,RH				
Control: Standard Heat Pmp				
CnfgID				
DownLd				
Back	Next	Save	SaveAs	

Figure 14s

Honeywell

T7350 Configuration Tool

Version: 0.0.d.18h

.....

▼ Select Existing Config

Figure 14t

Honeywell

T7350 Configuration Tool

Version: 0.0.d.18h

Override Outputs

Please connect PDA serial port to the T7350 using the serial cable & Thermostat Interface Module.

Figure 14u

Override

Delays: **ON** OFF

ManualMode: **Run** Manual

Y1: ▼ OFF **W1:** ▼ OFF

G: ▼ OFF **A1/W2/Y2** ▼ OFF

AC: 0 % **AH:** 0 %

Spin Speed **1X** 10X

Figure 14v

Override

Delays: **ON** OFF

ManualMode: **Run** Manual

Y1: ▼ OFF **W1:** ▼ OFF

Y2: ▼ OFF **W2:** ▼ OFF

Y3: ▼ OFF **W3/Y4:** ▼ OFF

G: ▼ OFF **aux:** ▼ OFF

Figure 14w

Override

Delays: **ON** OFF

ManualMode: **Run** Manual

Y1: ▼ OFF **W1:** ▼ OFF

Y2: ▼ OFF **W2:** ▼ OFF

Y3: ▼ OFF **W3/Y4:** ▼ OFF

G: ▼ OFF **aux:** ▼ OFF

Manual Override

Figure 14x




Figure 14y




Figure 14z




FIGURE 15




FIGURE 16




FIGURE 17




FIGURE 18




FIGURE 19




FIGURE 20a




FIGURE 20b





Figure 21



KEY:




FIGURE 22




FIGURE 23




FIGURE 24




FIGURE 25




FIGURE 26




FIGURE 27

Honeywell
T7350 Configuration Tool
Version: diag1

Override	Monitor Data
Set Clock	Commission
Temp SetPts	Holidays
Upload Config	Wkly Schedule
New Config	

▼ Select Existing Config

FIGURE 28a

Honeywell
T7350 Configuration Tool
Version: diag1

T7350 Online Diagnostics

Please connect PDA serial port to the T7350 using the serial cable & Thermostat Interface Module.

OK Cancel

FIGURE 28b

Commission Summary

Sensors: Failed
Fan/Aux: UnTested
Cooling: OK
Heating: OK
Error Summary:
 DISCHARGE AIR SENSOR FAILURE:
 Temperature sensor is configured
 and is out of range or disconnected.
 REMOTE OUTDOOR AIR SENSOR

Back Next Close

FIGURE 28c

Sensors

	Valid
RoomTemp: 73 F	<input type="checkbox"/>
Remote SetPt: -5	<input type="checkbox"/>
Remote Bypass: OFF	<input type="checkbox"/>
Room Rel Humidity: 55 %	<input type="checkbox"/>
Occupancy Sensor: OFF	<input type="checkbox"/>
Discharge AirTemp: Failed	
Outdoor AirTemp: 60 F	<input type="checkbox"/>

Back Next Update Test

FIGURE 29a

Sensors

	Valid
RoomTemp: 73 F	<input type="checkbox"/>
Remote SetPt: -5	<input type="checkbox"/>
Remote Bypass: OFF	<input type="checkbox"/>

Testing Room Temp

Room Temp: 73F
 Please confirm Room Temperature.

Pass Fail

FIGURE 29b

Sensors

	Valid
RoomTemp: 73 F	<input checked="" type="checkbox"/>
Remote SetPt: -5	<input type="checkbox"/>

Testing Remote SetPt

Remote SetPt: -1
 Please rotate remote setp int t the full - position (CCW) and tap OK.

OK

FIGURE 29c

Sensors	
RoomTemp: 73 F	Valid <input checked="" type="checkbox"/>
Testing Remote SetPt	
<p>? Full - setting validated. Remote SetPt: -5 Please rotate remote setpoint to the full + position (CW) and tap OK.</p>	
<input type="button" value="OK"/>	

FIGURE 29d

Sensors	
RoomTemp: 73 F	Valid <input checked="" type="checkbox"/>
Remote SetPt: -5	<input checked="" type="checkbox"/>
Testing Remote SetPt	
<p>i Full + setting validated. Remote SetPt: +5 Setpoint test sequence completed.</p>	
<input type="button" value="OK"/>	

FIGURE 29e

Sensors	
RoomTemp: 73 F	Valid <input checked="" type="checkbox"/>
Remote SetPt: -5	<input checked="" type="checkbox"/>
Remote Bypass: OFF	<input checked="" type="checkbox"/>
Room Rel Humidity: 55 %	<input checked="" type="checkbox"/>
Occupancy Sensor: OFF	<input checked="" type="checkbox"/>
Discharge AirTemp: Failed	
Outdoor AirTemp: 60 F	<input checked="" type="checkbox"/>
<input type="button" value="Back"/> <input type="button" value="Next"/> <input type="button" value="Update"/> <input type="button" value="Test"/>	

FIGURE 29f

Fan/Auxiliary Equipment	
ManualMode: OFF	Valid
Fan - G: OFF	<input type="checkbox"/>
TimeOfDay - R1: OFF	<input type="checkbox"/>
<input type="button" value="Back"/> <input type="button" value="Next"/> <input type="button" value="Update"/> <input type="button" value="Test"/>	

FIGURE 30

Cooling Equipment	
ManualMode: OFF	
Fan Status: OFF	Valid
Clg Stage1 - Y1: OFF	<input type="checkbox"/>
Clg Stage2 - Y2: OFF	<input type="checkbox"/>
Clg Stage3 - Y3: OFF	<input type="checkbox"/>
<input type="button" value="Back"/> <input type="button" value="Next"/> <input type="button" value="Update"/> <input type="button" value="Test"/>	

FIGURE 31a

Cooling Equipment	
ManualMode: OFF	
Fan Status: OFF	Valid
Clg Stage1 - Y1: OFF	<input type="checkbox"/>
Testing Cooling Operation	
<p>? Fan Status: OFF</p> <p>Please confirm it is safe to start the Fan.</p>	
<input type="button" value="Yes"/> <input type="button" value="No"/>	

FIGURE 31b

Cooling Equipment	
ManualM de:	OFF
Fan Status:	OFF Valid
Clg Stage1 - Y1:	OFF <input type="checkbox"/>
Testing Cooling Operation	
<p>? Fan Status: ON</p> <p>Please confirm Fan operation.</p> <p>Pass Fail</p>	

FIGURE 31c

Cooling Equipment	
ManualM de:	OFF
Fan Status:	OFF Valid
Testing Cooling Stages	
<p>? Fan Status: ON</p> <p># of Stages: 0</p> <p>Please confirm it is safe to start Cooling Stages.</p> <p>Yes No</p>	

FIGURE 31d

Cooling Equipment	
ManualMode:	OFF
Fan Status:	OFF Valid
Clg Stage1 - Y1:	OFF <input type="checkbox"/>
Clg Stage2 - Y2:	OFF <input type="checkbox"/>
Testing Cooling Stages	
<p># of Stages: 1</p> <p>DischargeAirT: 78F</p> <p>CoilDeltaT: 0F</p> <p>Progress: </p> <p>Cancel</p>	

FIGURE 31e

Cooling Equipment	
ManualMode:	OFF
Fan Status:	OFF Valid
Clg Stage1 - Y1:	OFF <input type="checkbox"/>
Clg Stage2 - Y2:	OFF <input type="checkbox"/>
Testing Cooling Stages	
<p># of Stages: 1</p> <p>DischargeAirT: 73F</p> <p>CoilDeltaT: 5F</p> <p>Progress: </p> <p>Cancel</p>	

FIGURE 31f

Cooling Equipment	
ManualMode:	OFF
Fan Status:	OFF Valid
Clg Stage1 - Y1:	OFF <input type="checkbox"/>
Clg Stage2 - Y2:	OFF <input type="checkbox"/>
Testing Cooling Stages	
<p>Validated Stage 1</p> <p>Cooling Operation</p> <p>Pr gress: </p> <p>Cancel</p>	

FIGURE 31g

Cooling Equipment	
ManualMode:	OFF
Fan Status:	OFF Valid
Clg Stage1 - Y1:	OFF <input checked="" type="checkbox"/>
Clg Stage2 - Y2:	OFF <input checked="" type="checkbox"/>
Clg Stage3 - Y3:	OFF <input checked="" type="checkbox"/>
<p>Back Next Update Test</p>	

FIGURE 31h

Heating Equipment

ManualMode: OFF
 Fan Status: OFF Valid
 Htg Stage1 - W1: OFF ☐

Back Next Update Test

FIGURE 32a

Heating Equipment

ManualMode: OFF
 Fan Status: OFF Valid

Testing Heating Operation

? Fan Status: OFF

Please confirm Fan air flow is required for stage 1 heating.

Yes No

FIGURE 32b

Heating Equipment

ManualMode: OFF
 Fan Status: OFF Valid

Testing Heating Stages

? Htg Stage 1: OFF

Please confirm it is safe to activate Heating Stage contact.

Yes No

FIGURE 32c

Heating Equipment

ManualMode: OFF

Testing Heating Stages

? Htg Stage 1: ON

Please confirm Heating Stage 1 operation. For example, room baseboard heat is activated.

Pass Fail

FIGURE 32d

Heating Equipment

ManualMode: OFF
 Fan Status: OFF Valid
 Htg Stage1 - W1: OFF ☒

Back Next Update Test

FIGURE 32e




FIGURE 33